

APPENDIX - VIII

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

No. 11/DWSD/2025-26

Date : 29-07-2025

It is certified that an inspection team headed by B.K. PRASAD, TECHNICAL
MANAGER (Name of Officers
with designation) from D.W. & S. DIVISION, HAZARIBAGH (Name of
Department/Office) inspected the GALAXY HIGH SCHOOL, ALAGDIHA
PABRA ROAD, KATKAMSANDI, HAZARIBAGH (Name & Address of
the School) on 26-07-2025 and found that the GALAXY HIGH
SCHOOL (Name of school) has safe
drinking water facilities for the students and members of staff of the institution and is maintaining
the hygienic sanitation condition in the school building & the campus as per the norms
prescribed by the Central/State/U.T Govt.

The above valid for a period of 06 Month (28.01-2026)

Signature with Seal : _____

Name : _____

Designation : _____

29/07/2025
Authorized Signatory
Authorized Signatory
District Level Water Testing Laboratory
Hazaribagh, Jharkhand

To

GALAXY HIGH SCHOOL
ALAGDIHA, PABRA ROAD
KATKAMSANDI, HAZARIBAGH

(Name & Address of the Institution)



District Level Water Testing Laboratory, Hazaribagh

Test Report

Report No: 253	Group :- Water	Report Issue Date : 29.07.2025
Discipline :- Chemical, Biological	Sub - Group: Ground Water	Valid up to One Month from the date of issue.
Issued To:	GALAXY HIGH SCHOOL ALAGDIHA, PABRA ROAD, KATKAMSANDI, HAZARIBAGH-825319	
Sample Description / Type	G.W (Drinking Water)	
Sample Location	N/A	Sample Collected by
Date of Sample received	26.07.2025	Lab Rep Pankaj Ravi
Date of start of Analysis	26.07.2025	Sample Quantity / Packing
Date of Completion Analysis :	29.07.2025	2 L PVC Bottle
SAMPLE CODE:-	01	Temperature
		25±2°C
		Humidity
		50±15 % RH
		Sampling Procedure
		N/A



Test Result

Test Result						
Sl. No.	Parameter	Unit	Result	Method Reference	Specification as per BIS - 10500:2012 (Second Revision) Amendment - June 2015	
					Acceptable Limit (Max)	Permissible Limit (In Absence of Alternate source) (Max)
(A)	CHEMICAL PARAMETERS					
1	pH	-	7.60	APHA 23 rd Edition 2017-4500-H' B, (Electrometric Method)	6.5 - 8.5	No relaxation
2	Turbidity	NTU	0.5	APHA-23 rd Edition 2017-2130-A, (Nephelometric method)	1	5
3	Chloride (as Cl)	mg/L, Max	40	APHA-23 rd Edition 2017-4500- B, (Argentometric method)	250	1000
4	Total Hardness as CaCO ₃	mg/L, Max	160	APHA-23 rd Edition 2017-2340-C (EDTA Titrimetric method)	200	600
5	Total Alkalinity as CaCO ₃	mg/L, Max	140	APHA-23 rd Edition 2017-2320-B, (Titration Method)	200	600
6	Calcium as Ca ⁺	mg/L, Max	24.18	APHA-23 rd Edition 2017-3500-Ca-B, (EDTA Titrimetric Method)	75	200
7	Magnesium as Mg ⁺	mg/L, Max	12.14	APHA-23 rd Edition 2017-3500-Mg-B, (EDTA Titrimetric Method)	30	100
8	Fluoride as F	mg/L, Max	0.18	APHA 23 rd Ed. 2017-4500 F' C, (Ion selective electrode method)	1.0	1.50
9	Colour	CU (Hazen)	>1	APHA 23 rd Edition (Visual Comparison Method)	5	15
10	Odour	--	Agreeable	IS 3025 (Part-5)	Agreeable	Agreeable
(B)	BIOLOGICAL PARAMETERS					
11	Total Coliform	CFU/100 mL	0	APHA 23 rd Ed. 2017-9222B (Membrane Filter Technique)	Shall not be detectable in any 100 mL Sample	
12	Thermotolerant (Fecal) Coliform/ E. Coli	CFU/100 mL	0	APHA 23 rd Ed. 2017-9222D (Membrane Filter Technique)	Shall not be detectable in any 100 mL Sample	
Remarks :- According to above parameters Water is fit for drinking Yes () / No ()						
Specific comments :-						

Remarks :- According to above parameters Water is fit for drinking Yes () / No ()

Specific contractual notes :-

1. The results listed refer only to the tested sample and applicable parameter.
2. This report shall not be reproduced except in full without approval of the laboratory.
3. This report results apply to the sample as received.
4. This report results relate only to the items tested.
5. This report, in full or in part, shall not be used for advertising or as evidence in any court of law.
6. Tested Sample shall be retained up to seven days from the date of issue of the test report
7. The liability of the laboratory is limited to the invoiced amount.
8. All disputes are subjected to the Hazaribagh Jurisdiction.
9. NOTE :- BDL:-Below Detection Limit

Reviewed by	Authorized by
 B.K. Prasad 29/07/2025	 Mr. Anish Kumar 29/07/2025
Mr. B.K. Prasad	Quality Manager
Technical Manager	District Level Water Testing Laboratory WAS Division, Hazaribagh

.....End of Report.....